

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: February 21, 2017
Date of Addendum: January 20, 2017

B.O.	Proposal ID	Proposal Work Type	County	Project Number	Addendum
106	52-5557-620	PCC PAVEMENT - GRADE & REPLACE	JOHNSON	STP-U-5557(620)--70-52	21FEB106A01

Make the following changes to the PROPOSAL SCHEDULE OF PRICES:

Change Proposal Line No. 0190 2435-0251000 INTAKE, SW-510:
From: 14.000 EACH
To: 9.000 EACH

Add Proposal Line No. 0701 2435-0251010 INTAKE, SW-510 MODIFIED; 5.000 EACH

ESTIMATE REFERENCE NOTE:

QUANTITY INCLUDES INTAKE N1, N2, N3, N4, AND N5 (REFER TO SHEET M.01 AND M.02). FOR THESE STRUCTURES, THE DIMENSION OF THE "SHORT WALL" AS IDENTIFIED ON STANDARD ROAD PLAN SW-510 SHALL BE 5'-0". PRECAST WALL OPENINGS SHALL LEAVE A MIMUMUM OF 6-INCH WALL WIDTH ON EITHER SIDE OF THE OPENING.

If the above changes are not made, they will be made as shown here.